

# DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur  
dwtlgsp1@gmail.com

To,

Shri Nangali Academic Public School  
BSF Road Gurdaspur

No.: DWTLGSP/2627/00010 Dated : 10/04/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SNB/26-27/2026 Dated: 09/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 09/04/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Gurdaspur

D/A : Test Report



**Authorized Signatory**  
**For, District Water Testing Laboratory**  
**Gurdaspur**

# DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur  
dwtlgsp1@gmail.com



TC-14032

## TEST REPORT

Name & Address of Customer : <b>Shri Nangali Academic Public School</b> <b>BSF Road Gurdaspur</b>			Customer Reference No.	No : <b>SNB/26-27/2026</b> Dated : <b>09/04/2026</b>		
			Sample Submitted by	Principal		
			Date of Sample Receipt	09/04/2026		
			Analysis Starting Date	09/04/2026		
			Analysis completion Date	10/04/2026		
Discipline : <b>Chemical Testing</b>			Group: <b>Water</b>			
ULR No.:	TC14032260000060F		Sample Type :	Water		
Test Report No.:	DWTLGSP/2627/00010		Date of Issue :	10/04/2026		
Registration no.:	DWTLGSP/REG2627/00011		Condition of Sample :	Sealed		
Collection Point:	Private Submersible		Quantity/Type of Bottle:	1000 ml / Plastic Bottles		
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :	Sri Nangali Academic Public School BSF Road Gurdaspur / NA		
Village :	Not Mentioned		Habitation :	Not Mentioned		
Block:	Not Mentioned		District :	Gurdaspur		
Latitude :	Not Mentioned		Longitude:	Not Mentioned		
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.3@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	260	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO <sub>3</sub> )	104	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO <sub>3</sub> )	124	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	25.65	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	14.58	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	13.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Pankaj Kumar  
Quality Manager  
Authorized Signatory  
For, District Water Testing Laboratory  
Gurdaspur

----- End of the Test Report -----